Workshop on the Data Utilization of Greenhouse Gases Observing Satellite (GOSAT)

"IBUKI"

Outline of GOSAT Spacecraft and TANSO Sensor

November 5, 2008

Takashi Hamazaki Project Manager GOSAT Project Team

Japan Aerospace Exploration Agency





1. GOSAT OVERVIEW




GOSAT is;

- *The Greenhouse gases Observing SATellite.
- *A satellite to monitor global distribution of Greenhouse Gases (GHG);
 - Carbon dioxide and Methane at 100-1000km spatial scale
 - with relative accuracy of 0.3-1% (1-4ppm) for CO2 and 0.6-2% (10-34ppb) for CH4
- A joint project of
 - JAXA (Japan Aerospace Exploration Agency),
 - MOE (Ministry of the Environment) and
 - NIES (National Institute for Environmental Studies).
- ★Scheduled to be launched by Japan's H-IIA launch vehicle in early 2009 from Tanegashima Space Center
- Recently named as "IBUKI"







GOSAT

*

ClobateFrequentobservation★ single



OISONIA



Environmental Studies).



- Sensor Development (Partial Funding Support
- Data use for Policy Development
 - Algorithms development
 - Data use for science
 - Data processing(L2-4)
 - Validation







JAXA

- Satellite devel
- H-IIA launch
- Satellite operation
- Data acquisition
- Calibration

GOSAT Science Team

Scientific Advisory





	The second second second			
Size	Main	1.8m x 2.0m x 3.7m		
	body	(Wing Span 13.7m)		
	Dody	(,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,		
Mass	Total	1,750kg		
Power	Total	3.8KW		
Life Span	5 years			
Orbit	sun synchronous orbit			
	Local time	13:00+/-0:15(Descending)		
	Altitude	666km		
	Inclination	98deg		
	Re-visit	3 days		
Launch	aunch Vehicle H-IIA			
	Schedule	Jan. 21 st , 2009		



H-IIA Launch Vehicle







2. MISSION(TANSO) OVERVIEW



TANSO=<u>Thermal And Near infrared Sensor</u> for carbon Observation

TANSO-FTS
(Fourier Transform Spectrometer)






TANSO-CAI
(Cloud and Aerosol
Imager)



Principle of the Observation






absorption 水蒸気の吸収 1.80 1.85

GHGs absorb specific infrared spectrum

Reflection on the Earth Surface

Workshop on the Data Utilization of Greenhouse Gases Observing Satellite November 5,20083










Ground Pointing Mechanism and Fore optics	Configuration Pointing Field of view	2-axes particularly ground personal per	35 deg)		1 7 7
Fourier Transform Spectrometer	Speed Spectral ch Obs. band (micron)	4, 2, 1.1 sec 1P, 1S 0.75-0.78	/ 1 Interferod 2P, 2S 1.56-1.72		5.5 4.3
	Resolution (cm ⁻¹)	0.2	0.2		
	Detector	Si	InGaAs	InGaAs	
	Calibration	Solar Irradic Moon, Diod	Blackbody, Deep space		



ectra











	eration mode	Description			
	n day time	Observation in the short waveler all intraned bands are			
mode I		Observation in the thermal in to establish the space calibration			
		The operation of thermal infrared observation is suspended and mechanism is locked and TANSO-CAI is assumed as set to the All off me (In case of a failure of one of the solar paddles or other similar events) * The observation time is limited to ten minutes per orbit, and the sensor is set Standby II mode for the rest of the time.			
Specific Sunglint observ.		Observation of the sunglint points according to the commands.			
mode Specific points observation		Observation of the specified points according to the commands. "Specific points" include lakes, validation sites, ground-based CO2 observatories etc.			
Calibration mode	Lunar calibration	Calibration using the moon in the SWIR bands once a year, as necessary. This calibration is performed by rotating GOSAT to point to the moon and orienting the sensor's FOV toward the moon using the pointing mechanism.			
Solar irradiance calibration		Calibration using the solar irradiance for every orbit when the satellite is in sunlight and the ground surface is in shade. This calibration takes place at rise of the sun.			
	Instrument function calibration	Calibration of the instrument function by irradiating a 1.55 μ m wavelength semiconductor laser light.			
	Electrical calibration	Calibration of the signal processing in the analogue signal processor and beyond, by inputting a reference voltage signal.			








performed at regular intervals.









Regular Observation Pattern
(5 points in the cross-track dir

Specific Points
Observaton Pattern


(5 points in the cross-track direction)

Workshop on the Data Utilization of Greenhouse Gases Observing Satellite November 5,2008 5-



ne or







lest k



The proportion of the minimum sensing

band	1		2		3		4
	P	S	P	S	P	S	
	93.0	92.2	92.8	85.9	86.8	11.9	46.3(700-1400 28.6(1400-1800c)

- The out of band characteristics

band	1		2		3		4	
out of band (µm)	<0.746	>0.787	<1.471	>2.000	<1.812	>2.222	<5.56	>14.29
results (%)	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1



st Re.



Wave- length* (cm ⁻¹)	Spectral radiance* (W/cm²/sr /cm ⁻¹)	result
13050	5.5e-7	345
		246
		322
	3.8e-7	
700	280K	283
	length* (cm ⁻¹) 13050 6200	length* (cm ⁻¹) radiance* (W/cm ² /sr /cm ⁻¹) 13050 5.5e-7 6200 5.2e-7

^{*} The specification is defined at these value

	gain	Н	M	L
1				
1	NS		7.39	
		9.62 L	8.7/	
1	25 VI	>10	>10	9.79
	3P	8.98	9.02	7.85
	35	8.18	8.64	7.85
		NA	9.49	NA

The output voltage when the maximum radiance (below table) on each gain is observed.

Gain	Spectral radiance (W/cm²/sr/cm ⁻¹)						
	Band 1 Band 2 Band 3 Band 4						
Н	5.5e-7	5.2e-7	3.8e-7	NA			
М	1.8e-6	1.7e-6	1.3e-6	340K			
L	5.5e-6	5.2e-6	3.8e-6	NA			




Tesi



he propo	tion of the minimum
	naximum one in IFOV

band	AT/CT	result(%)
	AT &	95.34
	CT	96.48
		93.61
<u> </u>		92.83
2S	AT	92.86
23	CT	91.75
3P	AT	91.11
Jr	СТ	90.12
3\$	AT	93.46
55	СТ	95.49
4	AT	84.75
4	СТ	80.81





Workshop on the Data Utilization of Greenhouse Gases Observing Satellite November 5,200819






olarization sensitivity

Mode	bands	Specifi- cation	result
AT, CT=		<34%	24.9%
	2	<38%	27.9%
	3	<38%	29.3%
			19.9%
			27.0%
AT= 20	1	<34%	27.4%
degrees	2	<38%	27.4%
	3	<38%	29.6%

Polarization Sensitivity=
$$\frac{P-S}{P+S}$$






est ke.



Instrument function FWHM

band	Band 1		Band 2		Band 3		Band 4
polarization	Р	S	Р	S	Р	S	0.24/
FWHM(cm-1)	0.367	0.356	0.258	0.257	0.262	0.263	0.246




Example of the interferogram-Band 2





- (1) The light through the gas cell filled with an EOV of FTS.
- (2) The strong light source was set aro
- (3) It was compared that the cases where the strong light seturned on and off.

The difference between two cases was under 0.1 %.



The test result of the stray light:

the red line shows the case that the light source was turned off, the blue line shows the case that the light source was turned on.

Workshop on the Data Utilization of Greenhouse Gases Observing Satellite November 5,200822-



Resul



- The stability of the sensitivity to the change in measured in the thermal and vacuum as
- The output under the high temperature mode and the change was calculated.
- The maximum change of the sensitivity per degree C is 0.365 % and the change of the temperature of the optical bench where the optics are placed is estimated under 0.5 degree C per one revolution.

Therefore the change of the sensitivity is under 0.18 %.

the stability of the sensitivity (%) per degree C

band	1		2		3	
	primary	redundant	primary	redundant	primary	redundant
Р	0.365	0.364	-0.315	-0.310	-0.003	-0.023
S	0.189	0.196	-0.325	-0.326	-0.101	-0.111



Specifications



TANSO-CAl is operated to TANSO-FTS to

- detect derosol spatial distribution
 cloud coverage
- retrieve scattering spectrol characteristics

of aerosol

Band	Observation	Center	IFOV	FOV	No of P
No.	Band (nm)	Wavelength (nm)			
1	372-387	380	0.5		
2	667-680	678	0.5	1000	2000
3	866-877	870	0.5	1000	2000
4	1560-1640	1620	1.5	750	500



Operation Mode



Operation m	ode	Description
Observation	mode	Observation of all bands
Calibration mode	Lunar calibration	Calibration using the moon and performed year, as necessary. This calibration is performed to taking GOSAN to point to the moon and orienting the sensor's FOV toward the moon simultaneously with FTS
	Electrical calibration	Calibration of the signal processing in the analogue signal processor and beyond, by inputting a reference voltage signal
	Night time calibration	Calibration of the offset level in the night time





OBSERVATION WAVELENGTH

band	1	2	3	4
center wavelength(µm)	0.3783 (0.380±0.005)	0.6734 (0.674± 0.005)	0.8720 (0.870±0.005)	(1.00
	0.018 (<0.02)	0.015 (<0.02)	0.014 (<0.02)	0.086 (<0.1)
out of band characteristics (%)	0.02(<0.360) 0.07(>0.400) 0.01(>0.700)	0.27(<0.658) 0.05(>0.692)	0.05(<0.840) 0.03(>0.890)	0.23(<1.





Band	FOV (deg)	IFOV (km)	S/N	Polarization sensitivity	MTF*:CT/AT	Sensitivity deviation between pixels**
	72.27 (>72.2)	0.497 (0.5±0.01)	274.4	0.018 (<0.03)	0.00270.75 05 0.20370.317)	(>70)
	72.28 (>72.2)		223.3	0.017 (<0.03)	0.4394/0.7310 (0.203/0.317)	85.7 (>70)
3		0.496 (0.5±0.01)		0.024 (<0.03)	0.2 <mark>343/0.6</mark> 957 (0.152/0.238)	86.1
4		1.494 (1.5±0.02)	449.1	0.019 (<0.03)		92.1 (>70)

The bracketed value are specification.

^{*}MTF is the value at the nadir

^{**} the output of the minimum output pixel when the output of the maximum output pixel is normalized to 100.





Dynamic Range

goin	Spec				
gain	band 1	band 2	band 3	band 4	
	155	212	22	35	
	208	-445	291	68	
		1254	777	201	
				V	

MTF

band	1		2		3		4	
	СТ	AT	CT	AT	CT	AT	CT	AT
edge	0.619	0.755	0.295	0.623	0.194	0.511	0.294	0.407
center	0.663	0.751	0.439	0.731	0.234	0.696	0.326	0.402
edge	0.661	0.763	0.313	0.641	0.194	0.333	0.257	0.399





Registration between ban

Band		СТ		AT			
	edge (-side)	center	Edge (+side)	edge (-side)	center	Edge (+side)	
		0.168	0.5	0.046	-0.028	-0.028	
2	-0.144	0.559	0.982	-0.376	-0.219	-0.098	
3	0	0					
4	0.095	0.125	-0.122	-0.006	-0.096	-0.120	

^{*}relative value to the band 3





The pre-launch calibration of TANSO were already and spectral characteristics.

The following items were evaluated as the pre-launce.

	items	equipment used for the evaluation
	instrument function	Integrated sphere (Arlamp) Tunable laser
	sensitivity	-fixed point blackbody and integrating sphere
100		-blackbody cavity
	IFOV(flatness of the sensitivity in the pixel)	-collimator
CAI	sensitivity	-fixed point blackbody
	bandwidth	-monochromator and collimator
	Registration between bands	-collimator





TANSO-FT	S			
band	1	2	3	4
pre-launch	0.92 %	1.65%	1.64 %	
on orbit	3.01 %	3.01 %	3.01%	de ou
	3.15%	3.44 %	3.43 %	